



V STAR FIRE & SAFETY SERVICE

31/163/DK135, DASHRATH KUNJ, SHAMSHABAD ROAD, AGRA-282001

Deals In:- All Fire & Safety Equipments

Ref. No. **VS-95/2026**

Date **05-10-2026**

FIRE EXTINGUISHER REFILLING CERTIFICATE

PARTY NAME: **प्रधानाचार्य शास्त्रीय अभिनव शहर कोलेज**

ADDRESS: **बिजौली, वाराणसी, आगरा**

THE DETAILS OF FIRE EXTINGUISHER IS GIVEN BELOW:-

Sr. No.	Description	Capacity	Qty.	Remarks
1.	Refilling ABC Powder	06Kg	02	OK
2.	Refilling CO2 Type	4.5kg	02	OK
—	—	—	—	—
—	—	—	—	—

Serial Number:- **VS-95/2026**

Maximum Working:- 15Kg/Cm2

Refilling Date:- **05-10-2026**

Next Refilling Date:- **04-10-2027**

This is certifying by V STAR FIRE SAFETY SERVICES on the following date, the above Fire Extinguisher was Refilling Accordance with Works Instruction W1-FA-147 Rev B.

Position: We Was Found the Fire Cylinders mast the Pressure test Acceptance Criteria specified. On the basic of above Inspection the Cylinder is pass for further use.

[Signature]
Authorised By:
V Star Fire Safety